

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

Holder of Certificate:	Alpha ESS Co., Ltd. No.1086, Bihua Road, Jinxin Street, Tongzhou District 226300 Nantong City, Jiangsu Province PEOPLE'S REPUBLIC OF CHINA
Product:	Converter Hybrid Inverter
Model(s):	SMILE-G3-T4-INV, SMILE-G3-T5-INV, SMILE-G3-T6-INV, SMILE-G3-T8-INV, SMILE-G3-T10-INV
Parameters:	Pleas see pages 2 to 8.
Applicable standards:	EN 50549-1:2019 EN 50549-10:2022

This Certificate of Conformity confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: www.tuvsud.com/ps-cert

Test report no.: 704092431901-00

Date, 2024-07-15



(Zhengdong Ma)

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

Model	SMILE-G3-T4-INV	SMILE-G3-T5-INV	SMILE-G3-T6-INV
DC input parameters:			
Maximum input voltage	DC 1000 V		
MPPT voltage range	DC 140, ..., 950 V		
Maximum input current	DC 16/16/16 A		
Isc PV (absolute maximum)	DC 24/24/24 A		
Battery input parameters:			
Battery type	LFP (LiFePO4)		
Battery voltage range	DC 90, ..., 700 V		
Rated charge current	DC 40 A		
Rated discharge current	DC 40 A		
AC-output parameters (Grid side):			
Rated output voltage	3/N/PE AC 230/400 V		
Rated frequency	50 Hz		
Rated Output Power	4 kW	5 kW	6 kW
Rated output apparent Power	4 kVA	5 kVA	6 kVA
Rated output current	AC 5.8 A	AC 7.3 A	AC 8.7 A
Power factor range	-0.8, ..., 1, ..., 0.8		

Model	SMILE-G3-T8-INV	SMILE-G3-T10-INV
DC input parameters:		
Maximum input voltage	DC 1000 V	
MPPT voltage range	DC 140, ..., 950 V	
Maximum input current	DC 16/16/16 A	
Isc PV (absolute maximum)	DC 24/24/24 A	
Battery input parameters:		
Battery type	LFP (LiFePO4)	
Battery voltage range	DC 90, ..., 700 V	
Rated charge current	DC 40 A	
Rated discharge current	DC 40 A	
AC-output parameters (Grid side):		
Rated output voltage	3/N/PE AC 230/400 V	
Rated frequency	50 Hz	
Rated Output Power	8 kW	10 kW
Rated output apparent Power	10 kVA	10 kVA
Rated output current	AC 11.6 A	AC 14.5 A
Power factor range	-0.8, ..., 1, ..., 0.8	

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

Evaluated protection function and operational capabilities

Clause(s) / subclause(s) of EN 50549-1:2019	Applicable clause(s) / subclause (s) of this document	Remarks, optional modes and constraints	Verdict
4.4.2 Operating frequency range	5.2.1 Frequency operating range	--	Pass
4.4.3 Minimal requirement for active power delivery at underfrequency	5.2.1 Frequency operating range	--	Pass
4.4.4 Continuous operating voltage range	5.2.2 Voltage operating range	--	Pass
4.5.2 Rate of change of frequency (ROCOF) immunity	5.3.1 Immunity to disturbances – Rated of change of frequency (ROCOF)	--	Pass
4.5.3.2 Generating plant with non-synchronous generating technology	5.3.3 Immunity to disturbances - Fault ride through, over-voltage (OVRT) and under-voltage (UVRT)	--	Pass
4.5.4 Over-voltage ride through (OVRT)	5.3.3 Immunity to disturbances - Fault ride through, over-voltage (OVRT) and under-voltage (UVRT)	--	Pass
4.6.1 Power response to overfrequency	5.4 Active response to frequency deviation	--	Pass
4.6.2 Power response to underfrequency	5.4 Active response to frequency deviation	--	Pass
4.7.2.2 Voltage support by reactive power, Capabilities	5.5.1 Power capabilities assessment	--	Pass
4.7.2.3 Voltage support by reactive power, Control modes	5.5.2 Voltage support by reactive power - test to determine the reactive power control modes	Q setp. Q(U) Cos φ setp. Cos φ (P)	Pass
4.7.2.3.2 Set point control modes	5.5.2.3 Verification procedure for set point control	Q setp. Cos φ setp.	Pass
4.7.2.3.3 Voltage related control modes	5.5.2.5 Verification procedure for power related control modes for reactive power	Q(U)	Pass
4.7.2.3.4 Power related control mode	5.5.2.5 Verification procedure for power related control modes for reactive power	Cos φ (P)	Pass
4.7.3 Voltage related active power reduction	5.6 Voltage related active power reduction - P(U)	P(U)	Pass
4.7.4.2.2 Zero current mode for converter connected generating technology	5.3.3 Immunity to disturbances - Fault ride through, over-voltage (OVRT) and under-voltage (UVRT)	--	Pass
4.9.3 Requirements on voltage and frequency protection	5.8.3 Verification procedure for generating plants to be connected to a LV distribution network with Interface protection as internal device	--	Pass
4.9.4 Means to detect island situation	5.8.6 Islanding detection	Active methods tested with a resonant circuit	Pass

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

		according to EN 62116	
4.10.2 Automatic reconnection after tripping	5.9.3 Automatic reconnection after tripping	--	Pass
4.10.3 Starting to generate electrical power	5.9.4 Starting to generate electrical power	--	Pass
4.11.1 Ceasing active power	5.10 Active power reduction on set point	--	Pass
4.11.2 Reduction of active power on set point	5.10 Active power reduction on set point	--	Pass
4.12 Remote information exchange	5.11 Remote information exchange	Standardized communication protocol not provided by manufacturer	N/A
4.13 single fault tolerance of interface protection system and interface switch	5.12 Requirements regarding single fault tolerance of interface protection system and interface switch	--	Pass

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

Evaluated parameter and parameter range

Specific technical requirement (e.g. grid codes)		EN 50549-1:2019			
Clause(s) / subclause(s) of EN 50549-1:2019	Parameter	Remarks/ additional information	Configurable value range	Default value	
4.4.2 Operating frequency range	47.0 – 47.5 Hz Duration	--	0 – 20 s	0 s	
	47.5 – 48.5 Hz Duration	--	30 – 90 min	30 min	
	48.5 – 49.0 Hz Duration	--	30 – 90 min	30 min	
	49.0 – 51.0 Hz Duration	--	not configurable	unlimited	
	51.0 – 51.5 Hz Duration	--	30 – 90 min	30 min	
	51.5 – 52 Hz Duration	--	0 – 15 min	0 s	
4.4.3 Minimal requirement for active power delivery at underfrequency	Reduction threshold	--	not configurable	49.5 Hz	
	Maximum reduction rate	--	not configurable	10 % P _M /Hz	
4.4.4 Continuous operating voltage range	Upper limit	--	not configurable	110% U _n	
	Lower limit	--	not configurable	85% U _n	
4.5.2 Rate of change of frequency (ROCOF) immunity	ROCOF withstand capability (defined with a sliding measurement window of 500 ms)	--	not configurable	2 Hz/s	
4.5.3.2 Under-voltage ride through (UVRT) Generating plant with non-synchronous generating technology	Maximum power resumption time	--	not configurable	1 s	
	Voltage-Time-Diagram	--	See figure 6 most stringent curve of EN 50549-1:2019	Time [s]	U [p.u.]
				0.0	0.2
				0.15	0.2
			1.5	0.85	
4.5.4 Over-voltage ride through (OVRT)	Voltage-Time-Diagram	--	not configurable See figure 8 of EN 50549-1:2019	Time [s]	U [p.u.]
				0.0	1.25
				0.1	1.25
				0.1	1.20
				5.0	1.20
				5.0	1.15
				60	1.15
60	1.10				
4.6.1 Power response to overfrequency	Threshold frequency f ₁	--	50.2 Hz – 52 Hz	50.2 Hz	
	Droop	--	2 % – 12 %	5 %	
	Power reference	--	P _M P _{max}	P _{max} for ESS	
	Intentional delay	--	0 – 2 s	0s	
	Deactivation threshold f _{stop}	--	50.0 Hz – f ₁	deactivated	
	Deactivation time t _{stop}	--	0 – 600 s	-	
	Acceptance of	--	yes no	yes	

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

	staged disconnection			
4.6.2 Power response to underfrequency	Threshold frequency f_1	--	49.8 Hz – 46 Hz	49.8 Hz
	Droop	--	2 – 12 %	5 %
	Power reference	--	$P_M P_{max}$	P_{max}
	Intentional delay	--	0 – 2 s	0 s
4.7.2.2 Voltage support by reactive power - Capabilities	Active factor / Reactive power (%Pd) range overexcited	--	0.8 – 1 / 60 % P_D – 0	0.8 – 1 / 60 % P_D – 0
	Active factor / Reactive power (%Pd) range underexcited	--	0.8 – 1 / 60 % P_D – 0	0.8 – 1 / 60 % P_D – 0
4.7.2.3 Voltage support by reactive power - Control modes	Enabled control mode	--	Q setp. Q(U) Cos φ setp. Cos φ (P)	Q setp.
4.7.2.3.2 Voltage support by reactive power - Setpoint control modes	Q setpoint and excitation	--	0 – 60 % P_D	0
	cos φ setpoint and excitation	--	1 – 0.8	1
4.7.2.3.3 Voltage support by reactive power - Voltage related control modes	Characteristic curve – Q (U)	--	--	Indicate default characteristic
	Point a	--	50% U_n – 100% U_n	93 % U_n
	Point b	--	50% U_n – 100% U_n	94 % U_n
	Point c	--	100% U_n – 120% U_n	106% U_n
	Point d	--	100% U_n – 120% U_n	108 % U_n
	Min. reactive power	--	0 – 60 % P_D (Q_{max} under)	60 % P_D
	Max. reactive power	--	0 – 60 % P_D (Q_{max} over)	60 % P_D
	Time constant	--	3 s – 60 s	3.0 s
	Min cos φ	--	0.0 – 1	0.4
	Lock in power	--	0 % – 20 %	20%
	Lock out power	--	0 % – 20 %	5%
4.7.2.3.4 Voltage support by reactive power - Power related control mode	Characteristic curve – Cos φ (P)	--	--	Indicate default characteristic
	Point a	--	0 – 100% P_n / PF:-0.8, ..., +0.8	15% P_n / PF=0.8
	Point b	--	0 – 100% P_n / PF:-0.8, ..., +0.8	20% P_n / PF=1
	Point c	--	0 – 100% P_n / PF:-0.8, ..., +0.8	80% P_n / PF=1
	Point d	--	0 – 100% P_n / PF:-0.8, ..., +0.8	90% P_n / PF=-0.9
	Cos φ	--	0.8 – 1	0.8
	Time constant	--	3 s – 60 s	3.33 s
	Lock in voltage	--	105 % U_n	deactivated
	Lock out voltage	--	100 % U_n	deactivated
4.7.3 Voltage related active power reduction	Characteristic curve - P (U)	--	--	Indicate default characteristic
	Point a	--	0 – 100% P_n / U:0 V, ..., 264.5 V	100% P_n / U=207 V
	Point b	--	0 – 100% P_n / U:0 V, ..., 264.5 V	100% P_n / U=230 V
	Point c	--	0 – 100% P_n / U:0 V, ..., 264.5 V	100% P_n / U=253 V

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

	Point d	--	0 – 100%P _n / U:0 V, ...,264.5 V	5%P _n / U=257.6 V	
	Time constant	--	3 s – 60 s	3.33 s	
4.7.4.2.2 Zero current mode for converter connected generating technology	Enabling	--	enable disable	disabled	
	Static voltage range overvoltage	--	100 %U _n – 120 %U _n	120 %U _n	
	Static voltage range undervoltage	--	20 %U _n – 100 %U _n	50 %U _n	
4.9.3 Requirements on voltage and frequency protection	Threshold for protection as dedicated device [in A or kW. kVA]	--	16 A – 250 kVA	Not specified, inverter integrated as default	
	Undervoltage threshold stage 1	--	0.2 U _n – 1 U _n	0.85U _n	
	Undervoltage operate time stage 1	--	0.1 s – 100 s	100 s	
	Undervoltage threshold stage 2	--	0.2 U _n – 1 U _n	0.5U _n	
	Undervoltage operate time stage 2	--	0.1 s – 5 s	5 s	
	Overvoltage threshold stage 1	--	1.0 U _n – 1.2 U _n	1.2U _n	
	Overvoltage operate time stage 1	--	0.1 s – 100 s	100 s	
	Overvoltage threshold stage 2	--	1.0 U _n – 1.3 U _n	1.3U _n	
	Overvoltage operate time stage 2	--	0.1 s – 5 s	5 s	
	Overvoltage threshold 10 min mean protection	--	1.0 U _n – 1.15 U _n	1.1U _n	
	Underfrequency threshold stage 1	--	47.0 Hz – 50.0 Hz	47.5 Hz	
	Underfrequency operate time stage 1	--	0.1 s – 100 s	100 s	
	Underfrequency threshold stage 2	--	47.0 Hz – 50.0 Hz	47 Hz	
	Underfrequency operate time stage 2	--	0.1 s – 5 s	5 s	
	Overfrequency threshold stage 1	--	50.0 Hz – 52.0 Hz	51.5Hz	
	Overfrequency operate time stage 1	--	0.1 s – 100 s	100 s	
	Overfrequency threshold stage 2	--	50.0 Hz – 52.0 Hz	52Hz	
	Overfrequency operate time stage 2	--	0.1 s – 5 s	5 s	
	4.10.2 Automatic reconnection after tripping	Lower frequency	--	47.0 Hz – 50.0 Hz	49.5 Hz
		Upper frequency	--	50.0 Hz – 52.0 Hz	50.2 Hz
Lower voltage		--	50 %U _n – 100 %U _n	85 %U _n	
Upper voltage		--	100 %U _n – 120 %U _n	110 %U _n	

Certificate of Conformity

No. ESY 002785 0014 Rev. 00

	Observation time	--	10 s – 600 s	60 s
	Active power increase gradient	--	5% – 3000%/min	10 %/min
4.10.3 Starting to generate electrical power	Lower frequency	--	47.0 Hz – 50.0 Hz	49.5 Hz
	Upper frequency	--	50.0 Hz – 52.0 Hz	50.1 Hz
	Lower voltage	--	50 %U _n – 100 %U _n	85 %U _n
	Upper voltage	--	100 %U _n – 120 %U _n	110 %U _n
	Observation time	--	10 s – 600 s	60 s
	Active power increase gradient	--	5% – 3000 %/min	disabled
4.11.1 Ceasing active power	Activation option	--	Can be achieved by Modbus communication protocol, APP or Neovolt cloud, decision should be made by the DSO and responsible party	
4.11.2 Reduction of active power on set point	Activation option	--	Can be achieved by Modbus communication protocol, APP or Neovolt cloud, decision should be made by the DSO and responsible party	
4.12 Remote information exchange	Available communication standards	--	Standardized communication protocol not provided by manufacturer	